



Universal Converter

URW 60

EN
English

Installation & Operating Manual
819696-02

Contents

Content of this Manual	4
Scope of delivery/Product package	4
How to use this Manual	5
Illustrations and symbols used	5
Hazard symbols in this Manual	5
Types of warning	6
Specialist terms/Abbreviations	7
Usage for the intended purpose	8
Improper use	8
Basic safety notes	9
Required personnel qualifications	9
Notes on product liability	9
Function	10
Possible combinations of functions and equipment.....	10
Technical data	11
Example name plate/Identification URW 60	13
Factory settings	13
Functional elements and dimensions	14
Installing the URW 60 universal converter	15
Electrical connection safety notes	15
Wiring diagram for the URW 60 universal converter	16
Electrical connection	17
Bus line, cable length and cross-section.....	17
Connecting the 24 V DC power supply.....	17
Connecting the 4-20 mA analogue input.....	17
Wiring diagram of CAN bus system	18
Example.....	18
Important notes on connecting the CAN bus system.....	18
Changing the equipment settings	19
Configuring the controller group and baud rate.....	20

Contents

- Bringing into service – starting, operation and malfunction..... 21**
 - Behaviour in the event of a malfunction 21
- System malfunctions..... 22**
 - Causes 22
 - Check the installation and configuration before systematic troubleshooting 22
 - Indication of system malfunctions..... 23
- What to do in the event of system malfunctions..... 23**
- Taking out of service 24**
- Disposal 24**
- Returning decontaminated equipment..... 24**
- Declaration of Conformity; Standards and Directives..... 25**

Content of this Manual

Product:

Universal Converter URW 60

First edition:

BAN 819696-00/08-2019cm

Applicable documents:

Installation & Operating Manual BAN 819696-01 for URB 60 Visual Display and Operating Unit

You can find the latest Installation & Operating Manuals on our website:

<http://www.gestra.com>

© Copyright

All rights reserved. Any misuse, particularly reproduction and dissemination to third parties, is not permitted. The General Terms & Conditions of GESTRA apply.

Scope of delivery/Product package

- 1 x Universal Converter URW 60
- 1 x Installation & Operating Manual

How to use this Manual

This Installation & Operating Manual describes the correct use of the URW 60 universal converter. It applies to all persons who integrate this equipment into control systems, install, bring into service, operate, maintain and dispose of this equipment. Anyone carrying out the above-mentioned activities must have read this Installation & Operating Manual and understood its contents.

- Read this Manual in full and follow all instructions given.
- Please also read the instructions for use of any accessories.
- The Installation & Operating Manual is part of the product package. Keep it in an easily accessible location.

Availability of this Installation & Operating Manual

- Make sure this Installation & Operating Manual is always available to the operator.
- If you pass on or sell the equipment to a third party, please also hand over the Installation & Operating Manual.

Illustrations and symbols used

1. Action to be taken

2.

- Lists
 - ◆ Bullet points in lists

A Keys to illustrations



Additional
information



Read the relevant
Installation & Operating Manual

Hazard symbols in this Manual



Danger zone/Dangerous situation



Danger of death from electric shock

Types of warning

DANGER

Warning of a dangerous situation that will result in death or serious injury.

WARNING

Warning of a dangerous situation that may possibly result in death or serious injury.

CAUTION

Warning of a situation that may result in minor or moderate injury.

ATTENTION

Warning of a situation that will result in damage to property or the environment.

Specialist terms/Abbreviations

Here, we explain some abbreviations, specialist terms, etc., which are used in this Manual.

CAN (Controller Area Network) bus

Data transmission standard and interface for connecting electronic equipment, sensors and control systems. Data can be sent and received.

TRV .. / NRG .. / LRG .. / SRL ..

GESTRA equipment and type designations, see page 8.

PhotoMOS output

PhotoMOS are a special kind of semiconductor relay, which use a light-emitting diode on the input side that is optically coupled to an output transistor. This type of electrically non-conductive connection makes sure the input and output circuits are electrically isolated from each other.

PI controller

Controller with proportional (P) and integral (I) control

SELV

Safety Extra Low Voltage

Usage for the intended purpose

The URW 60 universal converter can be used in combination with a level electrode (with 4-20 mA current output) in steam boilers and hot water installations, and in condensate and feedwater tanks.

Combinations

The combination of the URB 60 visual display and operating unit, NRR 2-6x level controller, URW 60 and level electrode (4-20 mA) creates a functional unit that can be used as a water level controller and limit switch in steam boilers and hot water installations, and in condensate and feedwater tanks.

Possible equipment combinations

Level controller	Level electrode	Universal converter (analogue to CAN bus)	Visual display and operating unit
NRR 2-60 NRR 2-61	Ext. 4-20 mA	URW 60	URB 60

Fig. 1

Key to Fig. 1:

NRR = level controller

URW = universal converter

URB = visual display and operating unit



To ensure the proper use of equipment during all types of use, please also read the Installation & Operating Manuals for the system components used.

- You will find the latest Installation & Operating Manuals for the system components named in **Fig. 1** on our website: <http://www.gestra.com>

Improper use



There is a danger of death due to explosion if the equipment is used in potentially explosive atmospheres.

Do not use the equipment in potentially explosive atmospheres.

Basic safety notes



There is a risk of electric shock during work on electrical systems.

- Always switch off the voltage to the equipment before performing work on the terminal strips.
- Check that the plant is not carrying live voltage before commencing work.



Faulty equipment jeopardises plant safety.

- If the URW 60 universal converter does not behave as described on page 21, it may be faulty.
- Perform failure analysis.
- Only replace faulty equipment with identical equipment from GESTRA.

Required personnel qualifications

Activity	Personnel	
Integration in control system	Specialist staff	Plant designer
Installation/electrical connection/ bringing into service	Specialist staff	Electrician/installer
Operation	Boiler service technician	Staff trained by the plant operator
Maintenance work	Specialist staff	Electrician
Refits	Specialist staff	Plant construction

Fig. 2

Notes on product liability

We the manufacturer cannot accept any liability for damages resulting from improper use of the equipment.

Function

The URW 60 universal converter converts the analogue 4-20 mA signals from a connected level electrode into CAN bus telegrams.

The data are transferred to an ISO 11898 CAN bus via the CANopen protocol.

Function tests and failure diagnosis are performed using the URB 60 visual display and operating unit.

The data telegrams contain the following information:

- Level values from electrodes
- Fault indications on the occurrence of faults in electronic or mechanical parts

Possible combinations of functions and equipment

Combining the URW 60 universal converter with an NRR 2-6x level controller, a level electrode with a current output of 4-20 mA and the URB 60 visual display and operating unit gives you the following common functions:

Universal converter	URW 60
Function	
Converts the 4-20 mA current signal from the connected level electrode into CAN bus telegrams.	●
Transmits the signals via CAN bus data telegrams to an NRR 2-6x level controller and the URB 60 visual display and operating unit.	●

Fig. 3

Technical data

Supply voltage

- 24 V DC +/-20%

Power consumption

- Max. 4 W

Current input

- Max. 0.2 A

Required external fuse

- M0.5A

Input/output

- Interface for CAN bus to ISO 11898, CANopen, insulated

Input

- 1 x analogue input IN / (4-20 mA)

Indicators and controls

- 1 x multicolour LED (orange, green)
 - ◆ orange = power up, malfunctions
 - ◆ green = running
- 1 x 4-pole code switch for setting the controller group and baud rate

Protection class

- III Safety Extra Low Voltage

IP rating to EN 60529

- Terminal box: IP 40
- Terminal strips: IP 20

Admissible ambient conditions

- Service temperature 0 °C – 55 °C (0 °C – 55 °C at power-on)
 - Storage temperature - 20 °C – 70 °C *
 - Transport temperature - 20 °C – 80 °C (< 100 hours) *
 - Air humidity max. 95%, non-condensing
- * Only switch on after a 24-hour defrosting period*

Technical data

Terminal box

- Terminal box material: Lower section of black polycarbonate (glass-fibre reinforced), front of grey polycarbonate
- 2 x 8-pole terminal strips, removable separately
- Max. cross-section per screw terminal:
 - ◆ 1 x 4.0 mm² solid, or
 - ◆ 1 x 2.5 mm² stranded with sleeve, or
 - ◆ 2 x 1.5 mm² stranded with sleeve
- Terminal box attachment: Mounting clip on support rail TH 35 (to EN 60715)

Weight

- Approx. 0.2 kg

Example name plate/Identification URW 60

 Betriebsanleitung beachten! See installation instruction!	2		3	
	4	5	6	
	15		7	17
	16			8
9				
10	18	 12345678-12345678		
	19			
12	20	UK CA	EAC	CE
	21			14

Fig. 4

- | | | |
|---|--|--|
| 1 Safety note
2 Equipment function
3 Equipment designation
4 Power consumption
5 IP rating
6 Operating data
(maximum ambient temperature) | 7 Power supply
8 Protection class
9 Wiring diagram
10 Component type approval
11 Material number-serial number
12 Manufacturer
13 Component type approval
14 Disposal information | 15 Measuring range in $\mu\text{S}/\text{cm}$
16 Measuring range in ppm
17 Cutout relay
18 Information on functional safety
19 Marking for limiters (STL) or monitors (STM)
20 Field for set limit value
21 Mode of operation in accordance with EN 60730-1 |
|---|--|--|




The date of production is printed on the side of the equipment.

Factory settings

The URW 60 universal converter is delivered ex-works with the following settings:

- Baud rate: 50 kbit/s (max. cable length 1000 m)
- Controller group: 1
- Code switch setting: Sliding switch, white (1 to 4 = OFF)



Configuring the controller group and baud rate, see page 20, **Fig. 9**.

Functional elements and dimensions




Fig. 5

- A** Upper terminal strip
- B** Front membrane with LED, see page 21
- C** Lower terminal strip
- D** 4-pole code switch, for setting the controller group and baud rate
- E** Terminal box
- F** Support rail TH 35



The code switch can be accessed by disconnecting and removing the lower terminal strip.

Equipment settings, see page 20.

Installing the URW 60 universal converter

The URW 60 universal converter snaps onto a TH 35 support rail in a control cabinet.

DANGER



There is a risk of electric shock during work on electrical systems.

- Switch off the voltage to the plant before you install the equipment.
- Check that the plant is not carrying live voltage before commencing work.

1. Before you install the equipment, switch off the voltage to the plant or secure the surrounding equipment in the control cabinet, if live, so it cannot be touched.
2. Carefully press the unit onto the support rail until the holder clips into place.

Electrical connection safety notes

DANGER



Incorrectly connecting the universal converter or any associated components is a danger to plant safety.

- Connect the universal converter and all associated components as shown in the wiring diagram **Fig. 6** in this Manual.
- Do not use unused terminals as jumpers or support terminals.

Wiring diagram for the URW 60 universal converter




Fig. 6

Electrical connection

Bus line, cable length and cross-section

- Use a shielded, multi-core, twisted-pair control cable, e.g. UNITRONIC® BUS CAN 2 x 2 x .. mm² or RE-2YCYV-fl 2 x 2 x .. mm², as the bus line.
- Pre-wired control cables (with connector and coupling) are available as accessories in various lengths.
- The baud rate is determined by the line length (transfer rate) between the bus terminal devices, and the conductor size is determined by the overall current input of the measuring sensors.
- As far as possible, route the bus line separately from power lines and protected from environmental influences.

Connecting the 24 V DC power supply

- The URW 60 universal converter is supplied with 24 V DC.
- A safety power supply unit that delivers a Safety Extra Low Voltage (SELV) must be used to supply the equipment with 24 V DC.
- Use an M0.5A fuse as an external fuse.

Connecting the 4-20 mA analogue input

- Use a shielded, multi-core control cable with a minimum conductor size of 0.5 mm², e.g. LIYCY 2 x 0.5 mm².
- Maximum cable length = 100 m.
- Route connecting cables separately from power lines.

Wiring diagram of CAN bus system

Example




Fig. 7

Important notes on connecting the CAN bus system

- A dedicated 24 V DC SELV power supply unit that is isolated from connected loads must be used to supply the SPECTORconnect system.
- Make sure wiring is in line, not in a star!
- Use a central earth to prevent differences in potential in plant parts.
 - ◆ Connect the bus line shields to one another all the way along, and connect to the central earthing point (CEP).
- If two or more system components are connected in a CAN bus network, a 120 Ω terminating resistor must be connected to the **first** and **last** devices between terminals C_L/C_H.
- The URW 60 universal converter is equipped with an internal terminating resistor.

To activate the internal terminating resistor in the URW 60 universal converter, insert a jumper between the terminals ("Option 120Ω" and "CH").
- The CAN bus network must not be interrupted during operation!

If it is, an alarm is triggered.

Changing the equipment settings

DANGER



Danger of death from electric shock if live connections on terminal strips are touched.

- Always switch off the voltage to the equipment before performing work on the terminal strips.
- Check that the plant is not carrying live voltage before commencing work.

You can change the baud rate and controller group of the URW 60 universal converter at any time using code switch **Ⓢ** (see **Fig. 5**).



Make changes before installing the universal converter, when access is easier.

You will need the following tools:

- Slotted screwdriver size 2.5, fully insulated

Proceed as follows:

1. Switch off the supply voltage to the equipment or plant.
2. Carefully unscrew the lower terminal strip with the screwdriver and pull off, see **Fig. 8**.
3. Set code switch **Ⓢ** (see **Fig. 5**) as desired, see page 20, **Fig. 9**.
4. When your changes are complete, put the terminal strip back on.




Fig. 8

Changing the equipment settings


For operation, you must define the controller group and baud rate for the universal converter using code switch **Ⓢ** Fig. 5.



Set the same baud rate for all bus nodes.

Code switch **Ⓢ - sliding switch, white**

Configuring the controller group and baud rate



URW 60 universal converter

Code switch Ⓢ					
S1	S2	S3	S4	Configuration	ID
OFF	OFF			Controller group 1 (default)	41
OFF	ON			Controller group 2	46
ON	OFF			Controller group 3	61
ON	ON			Controller group 4	66
		OFF		Baud rate 50 kbit/s (default)	
		ON		Baud rate 250 kbit/s	
			OFF	Reserve (default)	
			ON	Reserve	

Fig. 9



Configure the universal converter as described in the Installation & Operating Manual of the URB 60 visual display and operating unit.

- You will find the latest Installation & Operating Manuals for the system components named in **Fig. 1** on our website: <http://www.gestra.com>




Fig. 10

Multicolour LED (orange/green),
orange = power up/malfunction, green = running

Startup

During startup, the LED lights up orange.

Normal operation

During normal operation, when the supply voltage is on and the correct input signal (4-20 mA) is received, the LED lights up green.

Behaviour in the event of a malfunction

In the event of a malfunction, the LED lights up orange.



Faulty equipment jeopardises plant safety.

- If the URW 60 universal converter does not behave as described on this page, it may be faulty.
 - Perform failure analysis.
 - Only replace faulty equipment with identical equipment from GESTRA.
-

System malfunctions

Causes

System malfunctions occur if CAN bus components have been incorrectly installed or configured, if the equipment has overheated, if there is interference in the supply network or if electronic components are faulty.

Check the installation and configuration before systematic troubleshooting

Installation:

- Check that the installation location complies with the admissible ambient conditions in terms of temperature, vibration, interference sources, etc.

Wiring:

- Does the wiring conform to the wiring diagrams?
- Is the bus line polarity correct throughout?
- Is a 120 Ω terminating resistor connected to the terminal devices of the CAN bus line?

Controller group and baud rate configuration on the level controller:

- Are the controller group and baud rate correctly set on code switch .

Configuration of electrodes:

- Are the electrodes correctly set and has the measuring range been calibrated?

Baud rate:

- Is the cable length correct for the set baud rate?
- Is the baud rate identical for all devices?

DANGER




There is a risk of electric shock during work on electrical systems.

- Always switch off the voltage to the equipment before working on the terminal strips (installation, electrical connection, disassembly).
- Disconnect all poles of the supply cable from the mains and secure so they cannot be switched back on.
- Check that the plant is not carrying live voltage before commencing work.
- Interrupting the CAN bus during operation triggers an alarm.

System malfunctions

Indication of system malfunctions

Fig. 11



Multicolour LED (orange/green),
orange = power up/malfunction, green = running

Indication of malfunctions in the URW 60 universal converter	
Type of fault/malfunction	LED
Breakdown in CAN bus communication	orange
Incorrect input signal (4-20 mA)	orange
Interruption to power supply	off

Fig. 12

What to do in the event of system malfunctions



In the event of malfunctions or faults that cannot be remedied with the aid of this Installation & Operating Manual, please contact our service centre or authorised agent in your country.

Taking out of service

1. Switch off the supply voltage and the voltage to the equipment.
2. Check that the equipment is not live.
3. Unscrew and pull off the upper and lower terminal strips, see **Fig. 5 A; B**
4. Release the slider holder on the base of the equipment, and detach the URW 60 universal converter from the support rail.

Disposal

Dispose of the universal converter in accordance with statutory waste disposal regulations.

Returning decontaminated equipment

If products have come into contact with media that are hazardous to health, they must be drained and decontaminated before being returned to GESTRA.

Such media include solid, liquid or gaseous substances, mixtures of these, or radiation.

GESTRA can accept returned products only if accompanied by a completed and signed return note and also a completed and signed declaration of decontamination.



The return confirmation and declaration of decontamination must be attached to the returned goods and be accessible from the outside. Otherwise, the goods cannot be dealt with and will be returned, carriage unpaid.

Please proceed as follows:

1. Let GESTRA know about the return beforehand by e-mail or phone.
2. Wait until you have received the return confirmation from GESTRA.
3. Fill out the return confirmation (and declaration of decontamination) and send it with the products to GESTRA.

Declaration of Conformity Standards and Directives

You can find details on the conformity of the equipment and the applicable standards and directives in the Declaration of Conformity and associated certificates.

You can download the Declaration of Conformity from www.gestra.com and request relevant certificates by writing to the following address:

GESTRA GmbH

Münchener Straße 77

28215 Bremen

Germany

Tel. +49 421 3503 0

Fax +49 421 3503 393

e-mail info@de.gestra.com

Website www.gestra.com

Modifications to the equipment not approved by us will invalidate the Declarations of Conformity and certificates.



You can find our authorised agents around the world at:

www.gestra.com

GESTRA GmbH

Münchener Straße 77
28215 Bremen
Germany

Tel. +49 421 3503 0
Fax +49 421 3503 393
e-mail info@de.gestra.com
Website www.gestra.com

UK Importer: GESTRA UK Ltd

Unit 1 Sopwith Park, Royce Close,
West Portway Business Park, Andover,
Hampshire SP10 3TS
United Kingdom